



NATIONAL
ENVIRONMENTAL
TESTING, INC.

DEC 14 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

12/09/1998

NET Job Number: 98.08200
Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to NET, Inc. Indianapolis Division for analysis:

Project Description: TWICE WEEKLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
225737	2X WEEKLY - COMP	11/25/1998	11/25/1998

National Environmental Testing, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.

Project Representative

MIL0003002



NATIONAL
ENVIRONMENTAL
TESTING, INC.

DEC 14 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

12/09/1998

Job No.: 98.08200
Page 2 of 3

Date Received: 11/25/1998
Job Description: TWICE WEEKLY WASTEWATER

Sample Number / Sample I.D.			Sample Date/	Analyst &		Reporting
Parameters	Result	Flag	Units	Date Analyzed	Method	Limit
225737	2X WEEKLY - COMP		11/25/1998			
Iron, ICP	3.3		mg/L	psc / 12/02/1998	EPA 200.7	<0.10
Lead, ICP	<0.080		mg/L	psc / 12/02/1998	EPA 200.7	<0.080
Silver, ICP	<0.020		mg/L	psc / 12/02/1998	EPA 200.7	<0.020
Zinc, ICP	0.33		mg/L	psc / 12/02/1998	EPA 200.7	<0.020

MIL0003003



NATIONAL
ENVIRONMENTAL
TESTING, INC.

DEC 14 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

FIELD REPORT

JOB #: 98.08200
CLIENT: MILBANK MFG.
PROJECT: TWICE WEEKLY WASTEWATER
DATE: 11/25/98
SAMPLER(S): MTM/CAB

An ISCO model 3710 auto sampler was used in the composite mode of operation. The sampler was equipped with a plastic composite jug, tygon suction line, battery, ice, and strainer.

All reusable equipment is decontaminated withalconox, tap water, 5% nitric acid, and deionized water. New tygon suction tubing was used for the sampler. A stainless steel strainer was also used for the sampling event.

The sampler was set to take a sample every 30 minutes for 8 hours.

Monitoring start 7:30 on 11/24/98
Monitoring end 15:00 on 11/24/98

The composite sample was cloudy brown.

Notes: Samples were preserved, in the field, in the appropriate containers with any required preservative.

MIL0003004

